

Certificate of Product Approval

Certificate Number: 427a Issue: 13

KME ITALY S.p.A.

Via Della Repubblica 257 55051 Fornaci Di Barga Lucca Italy



s authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix naving complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below: MICO – KME Mineral Insulated Cables

Standard(s) (see Appendix for details)

BS 6387:2013 CWZ EN 60702-1:2002+A1:2015

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Kyloul.

Karen Coull

Certification Scheme Manager

9 October 2018

19 March 1999

Date of Issue Date of First issue

Signed for BRE Global Ltd.



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.







LPCB Ref. Product name MICO - KME Light Duty Mineral Insulated Cables 427a/01

Nominal csa of conductor (mm²)	Core Construction	BS 6387	EN 60702-1
1.0(2.3, 4 & 7	C, W, Z	Complies
1.5	2.3, 4 & 7	C, W, Z	Complies
2.5	2.3, 4 & 7	C, W, Z	Complies
4.0	2	C, W, Z	Complies

Uo/U 300/500V

Notes:

1. The above range is certified in both Bare and Served constructions.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Kulnel.

Karen Coull

9 October 2018

19 March 1999

Signed for BRE Global Ltd.

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.





Issue: 13



LPCB Ref.

MICO – KME Single Core Heavy Duty Mineral Insulated Cables

427a/02

Issue: 13

Nominal csa of conductor (mm²)	Core Construction	BS 6387	EN 60702-1
1.5	One	C, W, Z	Complies
2.5	One	C, W, Z	Complies
4.0	One	C, W, Z	Complies
6.0	One	C, W, Z	Complies
10	One	C, W, Z	Complies
16	One	C, W, Z	Complies
25	One	C, W, Z	Complies
35	One	C, W, Z	Complies
50	One	C, W, Z	Complies
70	One	C, W, Z	Complies
95	One	C, W, Z	Complies
120	One	C, W, Z	Complies

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Kulnel.

Karen Coull

9 October 2018

19 March 1999

Signed for BRE Global Ltd.

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.







LPCB Ref. Product name

MICO – KME Single Core Heavy Duty Mineral Insulated Cables

427a/02

Issue: 13

Nominal csa of conductor (mm²)	Core Construction	BS 6387	EN 60702-1
150	One	C, W, Z	Complies
185	One	C, W, Z	Complies
240	One	C, W, Z	Complies
300	One	C, W, Z	Complies
400	One	C, W, Z	Complies

Uo 750V

Notes:

- 1. The above range is certified in both Bare and Served constructions.
- 2. For cable with an outside diameter in excess of 20mm, the category Z tests were conducted in accordance with guidance from the manufacturer.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Kylnel.

Karen Coull

9 October 2018

19 March 1999

Signed for BRE Global Ltd.

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.







LPCB Ref. Product name

MICO – KME Multi-Core Heavy Duty Mineral Insulated Cables

427a/03

Issue: 13

Nominal csa of conductor (mm²)	Core Construction	BS 6387	EN 60702-1
1.5	2, 3, 4, 7, 12 & 19	C.W.Z	Complies
2.5	2, 3, 4, 7 & 12	C.W.Z	Complies
4.0	2, 3 & 4	C.W.Z	Complies
6.0	2, 3 & 4	C.W.Z	Complies
10	2, 3 & 4	C.W.Z	Complies
16	2, 3 & 4	C.W.Z	Complies
25	2, 3 & 4	C.W.Z	Complies

Uo/U 450/750V

Notes:

- 1. The above range is certified in both Bare and Served constructions.
- 2. For cable with an outside diameter in excess of 20mm, the category Z tests were conducted in accordance with guidance from the manufacturer.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Kylnel.

Karen Coull

9 October 2018

19 March 1999

Signed for BRE Global Ltd.

Certification Scheme Manager

Date of Issue

Date of First issue





This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



